

ОТЧЕТ  
о суточных параметрах теплоснабжения

26/01/19г. -25/02/19г.

Абонент: 419  
 Адрес: Славянская, 15  
 Тип расходуемого: \_\_\_\_\_  
 Договорчик: ВКТГ сет. N 001  
 Договорчик: \_\_\_\_\_  
 М сет. воды = \_\_\_\_\_ т.сут  
 Г под max = 30.00 м3/ч  
 Г под min = 0.08 м3/ч  
 Тхв = 10.00 °С  
 Т.сут Мгвс = \_\_\_\_\_ т.сут  
 Г обр max = 2.00 м3/ч  
 Г обр min = 1.00 м3/ч

Заводской номер 00172862 Ввод 1 СХЕМА ПОДКЛЮЧЕНИЯ 4 БД 1 ФТ=0 ТЗ=0 КС=0х06вв по 2.7

Дата	°С		dt	°С		V1	M1	M2	P1	P2	Qo	VHP	BOS	H.C.
	t1	t2		t1	t2									
26/01/19	83.35	52.33	31.02	87.50	84.89	84.89	7.00	7.00	7.00	7.00	2.636	24	0	
27/01/19	77.19	50.09	27.10	87.06	84.81	84.81	7.00	7.00	7.00	7.00	2.298	24	0	
28/01/19	77.29	49.91	27.38	86.54	84.22	84.22	7.00	7.00	7.00	7.00	2.305	24	0	
29/01/19	78.00	50.23	27.77	86.55	84.17	84.17	7.00	7.00	7.00	7.00	2.335	24	0	
30/01/19	73.49	48.43	25.06	85.92	83.88	83.88	7.00	7.00	7.00	7.00	2.102	24	0	
31/01/19	72.32	47.98	24.34	85.80	83.88	83.88	7.00	7.00	7.00	7.00	2.038	24	0	
01/02/19	71.71	47.71	24.00	85.72	83.80	83.80	7.00	7.00	7.00	7.00	2.009	24	0	
02/02/19	71.39	47.55	23.84	85.62	83.70	83.70	7.00	7.00	7.00	7.00	1.994	24	0	
03/02/19	70.92	47.49	23.43	85.27	83.35	83.35	7.00	7.00	7.00	7.00	1.950	24	0	
04/02/19	70.60	47.50	23.10	85.89	83.97	83.97	7.00	7.00	7.00	7.00	1.938	24	0	
05/02/19	70.26	47.40	22.86	85.58	83.67	83.67	7.00	7.00	7.00	7.00	1.908	24	0	
06/02/19	68.47	46.60	21.87	85.05	83.32	83.32	7.00	7.00	7.00	7.00	1.821	24	0	
07/02/19	68.25	46.18	22.07	84.87	83.15	83.15	7.00	7.00	7.00	7.00	1.834	24	0	
08/02/19	70.20	47.02	23.18	84.52	82.60	82.60	7.00	7.00	7.00	7.00	1.915	24	0	
09/02/19	69.73	46.65	23.08	84.00	82.09	82.09	7.00	7.00	7.00	7.00	1.893	24	0	
10/02/19	69.80	46.58	23.22	83.79	81.89	81.89	7.00	7.00	7.00	7.00	1.914	24	0	
11/02/19	69.98	46.79	23.19	83.39	82.47	82.47	7.00	7.00	7.00	7.00	1.883	24	0	
12/02/19	69.71	46.97	22.74	84.80	82.88	82.88	7.00	7.00	7.00	7.00	1.883	24	0	
13/02/19	68.71	46.47	22.24	84.64	82.88	82.88	7.00	7.00	7.00	7.00	1.839	24	0	
14/02/19	69.19	46.70	22.49	84.54	82.67	82.67	7.00	7.00	7.00	7.00	1.860	24	0	
15/02/19	69.00	46.56	22.44	84.84	83.02	83.02	7.00	7.00	7.00	7.00	1.860	24	0	
16/02/19	69.02	46.86	22.16	85.65	83.73	83.73	7.00	7.00	7.00	7.00	1.855	24	0	
17/02/19	68.78	46.60	22.18	85.43	83.55	83.55	7.00	7.00	7.00	7.00	1.852	24	0	
18/02/19	68.77	46.81	21.96	85.43	83.55	83.55	7.00	7.00	7.00	7.00	1.832	24	0	
19/02/19	71.51	48.06	23.45	85.73	83.79	83.79	7.00	7.00	7.00	7.00	1.962	24	0	
20/02/19	71.59	47.83	23.76	86.56	84.59	84.59	7.00	7.00	7.00	7.00	2.008	24	0	
21/02/19	70.46	47.31	23.15	85.95	84.03	84.03	7.00	7.00	7.00	7.00	1.944	24	0	
22/02/19	77.14	49.90	27.24	86.32	84.02	84.02	7.00	7.00	7.00	7.00	2.291	24	0	
23/02/19	79.21	50.63	28.58	86.51	84.15	84.15	7.00	7.00	7.00	7.00	2.407	24	0	
24/02/19	77.20	49.80	27.40	86.29	84.01	84.01	7.00	7.00	7.00	7.00	2.299	24	0	
25/02/19	73.41	48.23	25.18	86.03	83.97	83.97	7.00	7.00	7.00	7.00	2.108	24	0	
Итого:			2652.7	2590.70	2590.70		62.789	744	0					
Средние:	72.18	47.92	24.26				7.00	7.00						

Дата	V1		M1		M2		Qo	VHP	BOS
	М3	Т	Т	Т	Т	Гкал			
25/01/19 24:00	47798.14	46778.51	46778.51	46778.51	991.691	12395	8208		
25/02/19 24:00	50450.93	49369.21	49369.21	1054.480	13139	8208			
Итого:	2652.79	2590.70	2590.70	62.789	744	0			

Период нормальной работы 744ч  
 Период отсутств. счета тепл. энергии 0ч

Время работы прибора после сброса 21356ч

сл, 15 февраль 2019.txt

Представитель абонента

Представитель теплоснабж. организации

Плотников Н.В.

