

Абонент: 000 "УК ЖКО-25"  
Адрес: ул. Победы, 124  
Тепловычислитель, вк7 сэт. N 001  
Договорные расходы:  
М сэт. воды= \_\_\_\_\_ т.сут  
Тхв= 10.00°С

Договор N: 419  
Тип расхода: \_\_\_\_\_  
Пределы измерения:  
Г под max = 30.00 м3/ч  
Г под min = 0.08 м3/ч  
Г обр max = 30.00 м3/ч  
Г обр min = 0.08 м3/ч

Заводской номер 00273226

Ввод 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 Т3=0 КС=0X0628 ПО 2.7

Дата	t1		t2		dt	V1	M1	V2	M2	Mг	Q0	P1	P2	Q0	VНР	BOS	H.C.
	°С	°С	°С	°С													
26/01/19	69.48	51.43	18.05	116.38	113.88	103.07	101.79	12.09	7.00	5.00	2.056	24	0	0	0	0	
27/01/19	63.58	47.68	15.90	112.25	110.20	100.34	99.26	10.94	7.00	5.00	1.753	24	0	0	0	0	
28/01/19	66.61	49.01	17.60	110.03	107.87	98.23	97.05	10.82	7.00	5.00	1.900	24	0	0	0	0	
29/01/19	66.65	49.29	17.36	111.11	108.88	99.13	97.93	10.95	7.00	5.00	1.894	24	0	0	0	0	
30/01/19	62.86	47.59	15.27	108.69	106.72	97.70	96.71	10.01	7.00	5.00	1.631	24	0	0	0	0	
31/01/19	62.44	47.46	15.98	108.01	106.09	97.21	96.25	9.84	7.00	5.00	1.592	24	0	0	0	0	
01/02/19	62.97	45.92	15.12	79.31	77.89	72.38	71.64	6.25	7.00	5.00	1.180	19	5	5	5	5	
02/02/19	61.02	42.66	14.79	89.93	88.39	82.88	82.10	6.29	7.00	5.00	1.338	24	0	0	0	0	
03/02/19	57.45	42.66	14.79	87.78	86.44	80.28	79.61	6.83	7.00	5.00	1.279	24	0	0	0	0	
04/02/19	57.51	43.00	14.51	89.78	88.46	82.36	81.66	6.80	7.00	5.00	1.285	24	0	0	0	0	
05/02/19	58.58	44.32	14.26	98.08	96.50	90.15	89.32	7.18	7.00	5.00	1.379	24	0	0	0	0	
06/02/19	59.97	45.43	14.54	72.28	71.09	67.16	66.48	4.62	7.00	5.00	1.034	18	6	6	6	6	
07/02/19	61.55	46.72	14.83	100.32	98.58	94.96	93.96	4.61	7.00	5.00	1.466	24	0	0	0	0	
08/02/19	63.43	48.32	15.11	105.95	104.05	100.77	99.64	4.41	7.00	5.00	1.575	24	0	0	0	0	
09/02/19	64.48	49.36	15.12	111.19	109.10	105.74	104.51	4.59	7.00	5.00	1.653	24	0	0	0	0	
10/02/19	64.15	49.12	15.03	108.56	106.55	102.87	101.65	4.90	7.00	5.00	1.605	24	0	0	0	0	
11/02/19	62.33	47.37	14.96	101.80	99.98	95.78	94.75	5.23	7.00	5.00	1.501	24	0	0	0	0	
12/02/19	60.32	46.06	14.26	93.95	92.39	88.26	87.35	5.04	7.00	5.00	1.317	22	2	2	2	2	
13/02/19	60.40	47.89	12.51	126.37	124.28	121.16	119.83	4.45	7.00	5.00	1.497	22	0	0	0	0	
14/02/19	62.52	49.24	13.28	114.37	112.33	110.05	108.80	3.53	7.00	5.00	1.559	24	0	0	0	0	
15/02/19	63.84	49.83	14.01	122.35	120.05	117.06	115.72	4.33	7.00	5.00	1.685	24	0	0	0	0	
16/02/19	61.05	46.90	14.15	106.58	104.75	100.46	99.44	5.31	7.00	5.00	1.485	24	0	0	0	0	
17/02/19	60.98	47.04	13.94	95.89	94.26	90.42	89.46	4.80	7.00	5.00	1.315	21	3	3	3	3	
18/02/19	62.18	47.99	14.19	112.58	110.59	106.45	105.26	5.33	7.00	5.00	1.571	24	0	0	0	0	
19/02/19	64.69	50.60	15.09	95.26	93.44	91.30	90.21	3.23	7.00	5.00	1.321	19	5	5	5	5	
20/02/19	63.29	48.10	15.19	100.19	98.38	94.90	93.86	4.52	7.00	5.00	1.497	23	1	1	1	1	
21/02/19	62.87	48.20	14.67	109.60	107.59	104.25	103.10	4.49	7.00	5.00	1.581	24	0	0	0	0	
22/02/19	69.06	51.59	17.47	110.47	108.12	104.88	103.59	4.53	7.00	5.00	1.893	24	0	0	0	0	
23/02/19	69.60	50.95	18.65	102.10	99.89	95.72	94.54	5.35	7.00	5.00	1.864	24	0	0	0	0	
24/02/19	69.01	51.28	17.73	103.48	101.26	97.69	96.50	4.76	7.00	5.00	1.799	24	0	0	0	0	
25/02/19	61.96	45.86	16.10	92.50	90.85	86.86	85.99	4.86	7.00	5.00	1.462	24	0	0	0	0	
Итого:				3197.14	3138.85	2980.48	2947.96	190.89	47.967	720	24						
Средние:	63.27	48.02	15.25					7.00	5.00	147.967	720	24					


Дата	V1		M1		V2		M2		Mг		Q0		VНР		BOS	
	М3	Т	М3	Т	М3	Т	М3	Т	М3	Т	М3	Т	М3	Т	М3	Т
25/01/19	24:00	30987.53	30464.10	27328.25	27044.97	3419.13	409.774	7312	11615							
25/02/19	24:00	34184.67	33602.95	30308.73	29992.93	3610.02	457.741	8032	11639							
Итого:		3197.14	3138.85	2980.48	2947.96	190.89	47.967	720	24							

Период нормальной работы 720ч  
Период отсутствия. Счета тепл. энергии 24ч

Время работы прибора после сброса 19681ч

Представитель абонента

Плотников Н.Ю.



Представитель теплоснабж. организации

п06 124 фев 2019.схт