

Абонент: Славянская, 15
 Адрес: победы, 124
 Тепловычислитель ВКТ7 сет. N 001
 Договор N: 419
 Тип расходамера: _____
 Договорные расходы: _____
 М сет. Боды= _____ Т.сут Мгвс= _____ Т.сут
 Г под max = 30.00 м3/ч
 Г обр max = 30.00 м3/ч
 Г под min = 0.08 м3/ч
 Г обр min = 0.08 м3/ч
 Тхв= 10.00°С

Заводской номер 00273226 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 ТЗ=0 КС=0X0628 ПО 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	Mг	Qo	VНР	ВОС
26/02/20	53.25	41.83	11.42	94.72	93.50	95.21	94.39	-0.89	7.00	5.00	1.068
27/02/20	51.25	40.66	10.59	94.13	93.01	94.66	93.94	-0.93	7.00	5.00	0.985
28/02/20	55.53	43.15	12.38	97.45	96.03	97.87	96.95	-0.92	7.00	5.00	1.193
29/02/20	56.19	43.58	12.61	97.85	96.46	98.28	96.39	-0.93	7.00	5.00	1.217
01/03/20	54.83	42.84	11.99	97.11	95.75	97.57	96.72	-0.97	7.00	5.00	1.152
02/03/20	52.07	41.08	10.99	94.14	92.95	94.65	93.83	-0.88	7.00	5.00	1.024
03/03/20	52.04	41.02	11.02	94.83	91.83	93.47	92.76	-0.98	7.00	5.00	1.034
04/03/20	50.19	39.95	10.24	92.92	91.83	93.47	90.85	-0.93	7.00	5.00	0.942
05/03/20	47.30	38.35	8.95	90.84	89.87	91.47	90.85	-0.98	7.00	5.00	0.805
06/03/20	48.23	38.88	9.35	91.74	90.72	92.33	91.63	-0.91	7.00	5.00	0.851
07/03/20	48.99	38.06	9.65	92.51	91.49	93.11	92.39	-0.90	7.00	5.00	0.886
08/03/20	46.66	38.94	8.60	90.71	89.80	91.35	90.73	-0.93	7.00	5.00	0.776
09/03/20	45.76	37.51	8.25	89.51	88.65	90.17	89.58	-0.93	7.00	5.00	0.734
10/03/20	44.47	36.88	7.69	88.12	87.28	88.80	88.23	-0.95	7.00	5.00	0.672
11/03/20	47.78	38.73	9.05	91.30	90.34	91.91	91.19	-0.85	7.00	5.00	0.818
12/03/20	48.69	39.33	9.36	91.70	90.67	92.31	91.59	-0.92	7.00	5.00	0.783
13/03/20	47.20	38.41	8.79	90.16	89.20	90.80	90.11	-0.91	7.00	5.00	0.852
14/03/20	51.16	40.74	10.42	94.40	93.29	94.93	94.20	-0.91	7.00	5.00	0.972
15/03/20	58.90	45.16	13.74	98.87	97.25	99.24	98.28	-1.03	7.00	5.00	1.337
16/03/20	58.12	44.61	13.51	96.22	94.72	96.39	95.71	-0.99	7.00	5.00	1.281
17/03/20	55.62	43.15	12.47	92.94	91.66	93.41	92.62	-0.96	7.00	5.00	1.158
18/03/20	54.32	42.31	12.01	92.94	91.81	94.64	93.83	-1.02	7.00	5.00	1.104
19/03/20	50.60	40.09	10.51	88.84	87.76	89.37	88.72	-0.96	7.00	5.00	0.922
20/03/20	49.19	39.26	9.93	88.57	87.58	89.16	88.48	-0.90	7.00	5.00	0.870
21/03/20	52.55	41.27	11.28	91.60	90.43	92.10	91.36	-0.93	7.00	5.00	1.022
22/03/20	57.54	43.92	13.62	93.85	92.42	94.17	93.26	-0.84	7.00	5.00	1.262
23/03/20	60.19	45.96	14.23	100.09	98.41	100.45	99.41	-1.00	7.00	5.00	1.399
24/03/20	58.82	45.25	13.57	98.03	96.45	98.44	97.50	-1.05	7.00	5.00	1.309
25/03/20	56.18	43.35	12.83	92.96	91.59	93.36	92.53	-0.94	7.00	5.00	1.177
Итого:				2710.31	2675.55	2725.11	2702.79	-27.24	7.00	5.00	129.605
Средние:	52.32	41.27	11.05								1696

Дата	V1		M1		V2		M2		Mг		Qo	VНР	ВОС
	МЗ	Т	МЗ	Т	МЗ	Т	МЗ	Т					
25/02/20	24.00	48977.33	48191.08	44682.28	44241.55	3949.53	632.195	11811	16620				
25/03/20	24.00	51687.63	50866.63	47407.43	46944.34	3922.29	661.800	12507	16620				
Итого:	2710.30	2675.55	2725.15	2702.79	-27.24	29.605	696	0					

Период нормальной работы 696ч
 Период отсутствия. Счета Тепл.энергии 0ч
 Время работы прибора после сброса 29138ч