

ОТЧЕТ

о суточных параметрах теплоснабжения

26/01/22г. - 23/02/22г.

Договор N:419

Тип расходомера: _____

Пределы измерений: _____

Г под тах = 30.00 м3/ч Г под мин = 0.08 м3/ч

Г обр тах = 2.00 м3/ч Г обр мин = 1.00 м3/ч

Тхв = 10.00°C

Т.сут МГВС = _____ Т.сут

Заводской номер 00172862

ВВОД 1

СХЕМА ПОДКЛЮЧЕНИЯ 4

БД 1

ФТ=0

ТЗ=0

КС=0x06BV

ПО 2.7

Дата	t1		t2		dt	V1	M1	M2	P1	P2	Qo	VHP	BOS	HC
	°C	°C	°C	°C										
26/01/22	81.25	54.81	26.44	106.71	103.59	103.59	7.00	7.00	2.742	24	0			
27/01/22	81.02	54.72	26.30	105.91	102.86	102.86	7.00	7.00	2.706	24	0			
28/01/22	78.78	53.82	24.96	105.53	102.70	102.70	7.00	7.00	2.565	24	0			
29/01/22	74.41	51.97	22.44	105.31	102.69	102.69	7.00	7.00	2.303	24	0			
30/01/22	71.52	50.44	21.08	104.67	102.27	102.27	7.00	7.00	2.152	24	0			
31/01/22	71.27	50.28	20.99	104.95	102.55	102.55	7.00	7.00	2.151	24	0			
01/02/22	71.28	50.17	21.11	104.59	102.19	102.19	7.00	7.00	2.155	24	0			
02/02/22	71.30	50.21	21.09	104.50	102.10	102.10	7.00	7.00	2.151	24	0			
03/02/22	71.27	50.33	20.94	104.71	102.31	102.31	7.00	7.00	2.141	24	0			
04/02/22	71.45	50.22	21.23	103.98	101.58	101.58	7.00	7.00	2.152	24	0			
05/02/22	74.44	51.57	22.87	104.05	101.42	101.42	7.00	7.00	2.321	24	0			
06/02/22	73.07	51.20	21.87	105.00	102.48	102.48	7.00	7.00	2.240	24	0			
07/02/22	67.74	48.49	19.25	103.75	101.60	101.60	7.00	7.00	1.953	24	0			
08/02/22	67.93	48.59	19.34	103.23	101.07	101.07	7.00	7.00	1.951	24	0			
09/02/22	67.10	48.10	19.00	103.43	101.35	101.35	7.00	7.00	1.924	24	0			
10/02/22	66.32	47.64	18.68	104.04	101.99	101.99	7.00	7.00	1.901	24	0			
11/02/22	66.95	48.07	18.88	103.91	101.75	101.75	7.00	7.00	1.917	24	0			
12/02/22	67.22	48.18	19.04	103.47	101.31	101.31	7.00	7.00	1.927	24	0			
13/02/22	71.16	49.92	21.24	103.90	101.51	101.51	7.00	7.00	2.154	24	0			

611

14/02/22	71.11	50.05	21.06	104.15	101.75	101.75	7.00	7.00	2.141	24	0
15/02/22	71.78	50.63	21.15	104.40	101.99	101.99	7.00	7.00	2.156	24	0
16/02/22	68.76	48.94	19.82	103.45	101.28	101.28	7.00	7.00	2.007	24	0
17/02/22	66.95	48.25	18.70	104.04	101.95	101.95	7.00	7.00	1.903	24	0
18/02/22	64.67	47.29	17.38	103.69	101.66	101.66	7.00	7.00	1.766	24	0
19/02/22	61.94	45.10	16.84	99.48	97.73	97.73	7.00	7.00	1.642	24	0
20/02/22	61.88	45.44	16.44	102.30	100.56	100.56	7.00	7.00	1.649	24	0
21/02/22	61.84	45.55	16.29	102.25	100.49	100.49	7.00	7.00	1.635	24	0
22/02/22	61.92	45.59	16.33	102.29	100.51	100.51	7.00	7.00	1.639	24	0
23/02/22	62.01	45.61	16.40	102.51	100.74	100.74	7.00	7.00	1.654	24	0
Итого:				3014.2	2947.98	2947.98			59.698	696	0
Средние:	69.59	49.35	20.24				7.00	7.00			

Период нормальной работы 696ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 3527ч



Представитель абонента

Представитель теплоснабж. организации

